



AkzoNobel

Tomorrow's Answers Today

9th October 2017

Dear Sir,

SAS F170165 – Use of SolarTech Organic Cladding for use with Chartek 7 and Chartek 1620CSP

AkzoNobel can confirm that SolarTech PE55, supplied by Solartech International Ltd, can be used as part of a system where cellular glass is overlaid with SolarTech PE55 prior to the application of Chartek 7 or Chartek 1620CSP.

Lloyds register will approve the use of this material in accordance with the criteria stated in the type approval certificate and addendum.

Yours Faithfully

Robin Wade

Segment Manager - Technical Leadership Fire Protection